



Product Service

CERTIFICATE

No. B 118884 0002 Rev. 00

Holder of Certificate: **Jiangsu Deper Door Control Technology Co., Ltd.**
No. 42-1, Weier Road, Dongtai Economic Development Zone
224200 Jiangsu
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Powered pedestrian doors
Sliding door drive**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 7040121100801-00

Valid until: 2028-04-03

Date, 2023-04-06

(Bin Chen)



CERTIFICATE

No. B 118884 0002 Rev. 00

Model(s): 1) DSL-800, 2) DSL-1000

Parameters:

Rated voltage: 220-240VAC
 Rated frequency: 50-60Hz
 Rated input power: 1) 100W, 2) 120W
 Rated load: 1) 6Nm, 2) 8Nm
 Performance Level: d
 Category: 2
 Durability: 1 000 000 cycle
 Protection class: I
 Temperature range: -20 up to +50°C
 Degree of protection: IP20

The model DSL-800 and DSL-1000 can be used in combination with the following doors:

Operator	Max.	Max.	Min.
	door leaf weight	Door leaf width	Door leaf width
DSL-800	120kg*1 pcs	1600mm	600mm
DSL-800	100kg*2 pcs	1600mm	600mm
DSL-1000	180kg*1 pcs	1600mm	600mm
DSL-1000	160kg*2 pcs	1600mm	600mm

Tested according to: EN 16005:2012
 EN ISO 13849-1:2015
 EN 12100:2010
 EN 60335-1:2012/A15:2021
 EN 60335-2-103:2015